

Drinking Water Quality Regulator for Scotland

T: 0131 244 0224 | F: 0131 244 0211
E: regulator@dwqr.org.uk
www.dwqr.org.uk



Douglas Millican
Chief Executive
Scottish Water
Castle House
6 Castle Drive
Carnegie Campus
DUNFERMLINE
KY11 8GG

9 April 2015

Dear Douglas,

**Enforcement Notice Served Under Section 10 Water Industry (Scotland) Act 2002:
Burncrooks Water Treatment Works**

I wrote to you on 20 March 2015 attaching a copy of the enforcement notice that I planned to serve in relation to lead failures at consumer's taps in the Burncrooks and Blairlinnans water supply zone. I acknowledge Scottish Water's response of 27 March 2015 to this proposed enforcement notice and note that Scottish Water are progressing the requirements of the notice. I attach the final version of the enforcement notice which is unchanged from the draft notice.

If you have any queries regarding this letter please contact Matt Bower (0131 244 0743).

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Sue Petch'.

Sue Petch
Drinking Water Quality Regulator for Scotland

1D South
Victoria Quay
Edinburgh
EH6 6QQ



Enforcement Notice Under Section 10 of the Water Industry Act 2002

The Drinking Water Quality Regulator for Scotland ("the Regulator"), in exercise of the powers conferred by section 10(1) of the Water Industry (Scotland) Act 2002 hereby gives notice that she believes that Scottish Water has in the period 1 January 2014 to 31 December 2014, contravened and is likely to continue to contravene, regulation 4(2)(b) of the Public Water Supplies (Scotland) Regulations 2014 ("the Regulations"), and in consequence, Regulation 32 of the Regulations in relation to the provision of drinking water from Burncrooks Water Treatment Works to the following water supply zones by failing to ensure that water complies with the PCV for lead:

Therefore, Scottish Water is hereby required -

- i. by 30 October 2015, to install and commission a treatment process to eliminate, or reduce the risk to a minimum, of water containing in excess of the PCV of 10 µg/l Lead at consumer's taps and to have commenced a plan for optimisation of the above process.

Scottish Water shall continue to liaise closely with Greater Glasgow NHS Board and DWQR and, if necessary, implement any agreed measures to minimise risk to public health until such time as the actions identified in this enforcement notice are complete.

This notice takes effect 15 days after the date shown below.

DRINKING WATER QUALITY REGULATOR FOR SCOTLAND

Date: 10 April 2015