

Technical Inspection of**Balmichael WTW****Date of Inspection****Date 08-Mar-16****DWQR Staff Present**

Matt Bower, Moira Malcolm

Scottish Water Staff Present (& Titles)

Peter Brown, Les Stirling, Jim Hassan,

Chris McIntyre, Aleksandra Janus

Summary of Inspection

Balmichael WTW is a small membrane plant which serves the central and southern area of Arran. Water quality produced is generally excellent. The process consists of a ultrafiltration membrane followed by disinfection, which is generally a robust process for the type of raw water encountered. The process is operating well and the plant is well managed. The works is clean and tidy and staffing is adequate.