

Technical Inspection of**Londornoch WTW****Date of Inspection****Date** 28/10/2016**DWQR Staff Present**

Moira Malcolm

Scottish Water Staff Present (& Titles)**Summary of Inspection**

Londornoch WTW is a small works which uses raw water abstracted from Loch Laoigh and Loch Lannsaigh to serve Dornoch and neighbouring communities. Water quality produced is generally very good. The process consists of DAF and RGF followed by disinfection and pH correction, which generally works well at this site, despite the single stream nature of the plant. The process is operating well and the plant is well managed. The works is clean and tidy and staffing is adequate.