

**Lochinver WTW, North Region**

08/05/2019

**DWQR Staff Present**

Moira Malcolm

**Scottish Water Staff Present**

Michael Munro, Nathan George, Gary Campbell  
David Hill, Megan Galloway, Iain Bond, Robert White

**Summary of Inspection**

**Overall Summary**

Lochinver WTW is a small works serving Lochinver and environs. Regularly producing 28 M although design capacity is 56M (leakage reduction has significantly reduced the losses in the network). It has primary filtration and ultrafiltration membranes to treat water, followed by disinfection with sodium hypochlorite and pH correction. Staff are knowledgeable and operate the works efficiently.