



# SCOTTISH EXECUTIVE

## Environment Group

Mr George Ponton  
Strategy and Regulation  
Scottish Water  
Castle House  
6 Castle Drive  
Carnegie Campus  
DUNFERMLINE  
KY11 8GG

### Drinking Water Quality Unit

Victoria Quay  
Edinburgh EH6 6QQ

Telephone: 0131-244 0184  
Fax: 0131-244 0259  
Tim.hooton@scotland.gsi.gov.uk  
<http://www.scotland.gov.uk>

Your ref:  
Our ref: 2DWE/25/1

15 December 2003

Dear George

### INFORMATION LETTER 6/2003

#### The Water Supply (Water Quality) (Scotland) Regulations 2001 Monitoring for *Clostridium perfringens* (including spores).

#### Purpose

1 The purpose of this letter is to clarify the regulatory monitoring requirements for the *Clostridium perfringens* (including spores) parameter.

#### Background

2 Council Directive 98/83/EC on the quality of water intended for human consumption (the Directive) specifies parametric values for microbiological parameters and chemical parameters which are mandatory and must be complied with. The Directive additionally specifies parametric values for indicator parameters which are non-mandatory values for monitoring and action is taken only if the exceedence is a risk to health.

3 The Directive specifies the circumstances when check or audit monitoring should be applied to a parameter. The purpose of check monitoring is regularly to provide information on the organoleptic and microbiological quality of the water supplied as well as information on the effectiveness of drinking water treatment. The purpose of audit monitoring is to provide the information necessary to determine whether or not all of the Directive's parametric requirements are being complied with.

4 The Directive specifies *Clostridium perfringens* (including spores) as an Indicator Parameter. Its parametric value is 0 / 100 ml. A footnote to this parameter in Part C of the Directive states, inter alia, "this parameter need not be measured unless the water originates from or is influenced by surface water".



5 This footnote is further clarified by Note 2, Annex II, Table A, Check monitoring, which states that “[Check monitoring is] necessary only if the water originates from or is influenced by surface water. In all other cases, the parameters are in the list for audit monitoring”.

6 The Directive requirement for audit monitoring for *Clostridium perfringens* (including spores) when check monitoring is not necessary, has not been transposed clearly into the Water Supply (Water Quality) (Scotland) Regulations 2001 because no audit monitoring frequency is specified for the parameter.

### **Monitoring requirements under the Regulations**

7 The Regulations (Schedule 3 Table 1) clearly require all water supplies where the water originates from or is influenced by surface water to be monitored at the check frequency specified in Schedule 3 Table 2 and Table 3.

8 Regulation 6(5) includes the Directive requirement for audit monitoring where check monitoring is not required. Where this is the case, Scottish Water should monitor for the *Clostridium perfringens* (including spores) parameter at the audit frequencies for other parameters specified in Schedule 3 Table 2 and Table 3.

### **Analysis for the *Clostridium perfringens* (including spores) parameter**

9 The Unit confirms that laboratories may use the methods specified in the Standing Committee of Analysts’ publication “The Microbiology of Drinking Water 2003 (Part 6)”. This is available on the Environment Agency’s website [www.environment-agency.gov.uk](http://www.environment-agency.gov.uk).

### **Future monitoring requirements**

10 The United Kingdom has strongly supported both the conclusion of the European Advisory Group on Microbiology and the recommendation of the Microbiology Position Paper presented at the recent European Commission Water Quality Seminar on the future of the Directive that the *Clostridium perfringens* parameter should be deleted from the Directive, or at least be restricted to the audit frequency for all circumstances. The Commission is currently studying representations but it is unlikely that there will be an early change to any monitoring requirements.

### **Enquiries**

11 Any enquiries about this letter should be addressed to Dr Donald Reid, Drinking Water Quality Unit (telephone 0131 244 0278, [Donald.reid@scotland.gsi.gov.uk](mailto:Donald.reid@scotland.gsi.gov.uk))

12 Please acknowledge receipt by completion of the enclosed form.

Yours sincerely

**TIM HOOTON**  
**Head of Drinking Water Quality Unit**



Please complete the acknowledgement below and return it to:

Ewan J Young  
Scottish Executive  
Environment Group  
Drinking Water Quality Unit  
Area 1-H  
Victoria Quay  
EDINBURGH  
EH6 6QQ

I acknowledge receipt of Information Letter 6/2003  
**Monitoring for *Clostridium perfringens* (including spores).**

Signed \_\_\_\_\_

Name \_\_\_\_\_

Position \_\_\_\_\_

Address \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Date \_\_\_\_\_

