

Uig WTW Risk Based February 2026

Uig WTW is a small Dynasand filtration works on the Isle of Lewis supplying communities on the west coast of the island. Overall, the audit found the site to be well operated by knowledgeable staff, with good treatment control and generally good water quality performance. However, several concerns were identified relating to disinfection adequacy, Cryptosporidium risk, supernatant return management, and maintenance compliance.

DWQR identified eighteen findings. Proposed interventions to address DWQR's findings, along with completion dates and any interim mitigations that will be put in place have been agreed with Scottish Water.

DWQR will monitor completion of agreed interventions, and may request evidence of completion or re-visit the site.