

T: 0131-244 0186 F: 0131-244 0259  
E: colin.mclaren@scotland.gsi.gov.uk

Mr Peter Brown  
Scottish Water  
Castle House  
6 Castle Drive  
Carnegie Campus  
DUNFERMLINE  
Fife  
KY11 8GG

Your ref:  
Our ref: B2923913  
20 May 2009

Dear Peter

Regulation 27 letter 2/2009

**WATER SUPPLY (WATER QUALITY) (SCOTLAND) REGULATIONS 2001  
REGULATION 27(4)(C)  
APPROVAL OF TROJAN UV SWIFT SC FOR THE PURPOSES OF TESTING**

Thank you for your letter dated 6 May 2009 seeking Scottish Ministers' approval to introduce the Trojan UV Swift SC ultraviolet drinking water treatment process at Elphin water treatment works for the purposes of testing. After careful consideration, I have decided, on behalf of Scottish Ministers, to allow the use of this device under regulation 27(4)(c), which permits products to be introduced for the purposes of testing or research. However, regulation 27(7) requires that the use of products introduced under Regulation 27(4)(c) is time limited. Notice is hereby given therefore that Scottish Water may only use the above named device for the purpose of testing or research for a period of 12 months from the date of this letter.

I note that in parallel to the testing being undertaken by Scottish Water, the supplier will be pursuing the appropriate testing specification for compliance with Advice Sheet 8. I also note that in the event of failure of the supplier to obtain the appropriate certification, the above mentioned process will be removed from the public water supply at Elphin.

Any queries regarding the content of this letter should be addressed in the first instance to Philip Anderson ( 0131 244 0188).

Yours sincerely

COLIN MCLAREN