

Ringford WTW, South Region

17/09/2019

DWQR Staff Present

Moira Malcolm

Scottish Water Staff Present

Iain Skilling, Roy Caig, Elaine Noble, Amy Gove
Paul McElroy, Richard Henderson

Summary of Inspection

Overall Summary

Ringford WTW is a small treatment works that augments the Glengap supply for Kirkcudbright and surrounding area in Dumfries and Galloway. Water from boreholes is disinfected before being pumped to Muirhead service reservoir to be blended with Glengap water. No properties are fed directly from Ringford. The site has issues with flooding which are identified in the drinking water safety plan and should be addressed to protect the site and water quality.