

**Technical Inspection of Scottish Water's Water Network**

**Arran Network Audit**

**DWQR Staff Present**

Colette Robertson-Kellie

**Scottish Water Staff Present**

Mark Bunyan, Stephen Brown, David Hutton, David Seales, Gary Caig, Scott Gibson

**Date of Inspection**

8th September 2021

**Summary of Inspection**

**Overall Summary**

There were no network activities on Arran at the time of the audit, so the vehicle used for network maintenance was inspected. Overall, the cleanliness and order within the vehicle were good. The hand washing facilities were in working order, with a supply of soap and water available for staff. However, the tablets used to prepare a disinfectant solution were unlabelled and did not have a 'use by' date on them - it is recommended that this is addressed to ensure adequate Health and Safety precautions can be taken by staff and that the tablets are of the correct concentration for disinfection of surfaces. Additionally, the spray bottle used to apply disinfectant to pipes and fittings was incorrectly labelled as requiring 250 mg/l free chlorine instead of 1000 mg/l free chlorine.