

Clarklyhill SR Risk Based Audit June 2025

Clarklyhill is an above ground cylindrical service reservoir which feeds Burghhead in Moray.

This SR was audited due to a series of coliform failures in the autumn/winter of 2024. The first was attributed to the sample point, which was changed to reduce the length of pipework. The following two failures were attributed to ingress from vents surrounding the top of the SR. The SR was taken out of service, flood tested and cleaned. Further work to inspect and remediate the vents has been planned.

DWQR identified two findings. Proposed interventions to address DWQRs findings, along with completion dates and any interim mitigations that will be put in place have been agreed with Scottish Water.

DWQR will monitor completion of agreed interventions, and may request evidence of completion or re-visit the site.